

# NOTICE FOR ALL URD SERVICES!

You must give Cooperative advance notice of 7 (seven) working days before digging the trench...

## Requirements:

- Member responsible for **opening** and **closing** trench
- Primary trenches **must** be **42"** minimum depth
- Secondary trenches **must** be **30"** minimum depth

If the trench does not meet the above stated requirements upon arrival of the crew, the service will not be installed. Therefore, work by Cooperative will not be performed until the trench does meet these requirements.

There will be a **\$200.00** return trip charge for all jobs scheduled by the consumer or contractor failing to meet the above requirements. The \$200.00 fee will be waived if the consumer or contractor cancels the job by 4:00 PM on the previous day.

I hereby agree to the above mentioned conditions and will follow the conditions set forth by Southern Indiana Power.

Date: \_\_\_\_\_ Consumer Signature: \_\_\_\_\_

Contractor Signature: \_\_\_\_\_